

<b>HM&amp;V UTILITIES LTD</b> Unit 22, Gosport Business Centre, Aerodrome Road Gosport, Hants PO13 0FQ Telephone: 01329 848144 Fax: 07043 079960 Mobile: 07879 650805			DATE: 27th April 2018 REPORT NO 155-18 CONTRACT OUR REF:		
CUSTOMER ADDRESS:  PAINE MANWARING LIMITED   <p style="text-align: center;">HEATING</p>			SITE:  SOUTHERN SIDINGS UNIT B BLOCK 3		
PARAMETER	MAINS	10.45	11.45	12.45	13.45
pH	7.1	7.2	7.2	7.2	7.1
Conductivity/TDS	450	480	449	447	451
p.Alk					
m.Alk					
OH.Alk					
Chloride					
Ca/Total Hardness	400	400	400	400	400
Concentration Ratio					
Iron	0.0	0.0	0.0	0.0	0.0
Turbidity	CLEAR	CLOUDY	CLOUDY	CLOUDY	CLOUDY
Bacteria					
Nitrate					
Sulphite					
Glycol					
Copper	0.0	0.0	0.0	0.0	0.0
Molybdate					
Meter Reading					
Comments and actions :  Flushed out to within 10% of mains then dosed with inhibitor  Recommended level of Molybdate is above 1%					
Water treatment chemical	Dose	Time			
M27	3 litres				