

EVC Commissioning Certificate

DOCKET No.

106593



Southern Fire Alarms Ltd
2 Argyle Circus
Bognor Regis
West Sussex
PO21 1DS

t: 01243 870851
e: info@sfa-uk.com
w: www.sfa-uk.com

SFA Job No.	30465
Customer Name:	Paine Manwaring Electrical
Site Name:	Southern Gate Unit 3
Address:	Chichester
Post Code:	PO19
Date:	19/04/18
Engineer:	Antony Tucker

Design Responsibility: SFA Others

You are advised to maintain records of the EVC system for the lifetime of the system.

THE EXTENT OF LIABILITY OF THE SIGNATORY IS LIMITED TO THE SYSTEM DESCRIBED BELOW.

Extent of system covered by this certificate:

Commissioned new refuge system as per drawings 545/TSP/01/00/DR/A/2001 AND 2002.

Variations from the recommendations of BS 5839-9:2011, Clause 22

1	no new variations
2	
3	
4	
5	

Y	N	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

All equipment operates correctly

Installation work is as far as can be reasonably ascertained, of an acceptable standard

The entire system has been inspected and tested in accordance with BS5839-9:2011, Clause 22

The documentation described in BS5839-9:2011, Clause 23 has been provided to the user.

The system performs as required by the specification prepared by 545/tsp/01/00/dr/A/2001 and 2002 rev A.
..... a copy of which I/we have given.

The following work should be completed before/after (delete as applicable) the system becomes operational:

na

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the commissioning of the EVC system, particulars of which are set out above, CERTIFY that the said installation for which I/we have been responsible conforms to the best of my/our knowledge and belief with the recommendations of BS 5839-9:2011, Clause 22 except for the variations, if any, stated in this certificate.

Engineers Signature: Print: Antony Tucker Date: 19/04/18

For and on behalf of: Southern Fire Alarms Ltd, 2 Argyle Circus, Bognor Regis, West Sussex, PO21 1DS