

PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03854

Pressure Test Certificate

Contract <i>Southern Gate w.stirkland</i>	Job No: <i>CHO35043</i>	Test Date <i>08-02-18</i>
---	----------------------------	------------------------------

Section Tested - *unit 1*

- Boiler*
- Heating flow & Return Riser*
- All Heating on all floors in communal areas, corridors and w.c's*
- All Heating including Radiators on all floors in office areas*
-
-

Details of Test

Final Working Pressure of Supply *2* Bar Test pressure Applied *2* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *R Jones* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of *w.stirkland*

Print Name Here *JOHN SIMS. (SITE MANAGER)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511

enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03766

Pressure Test Certificate

Contract Southern Gate W. Stirland	Job No: CH035043	Test Date 05-01-2018
---------------------------------------	------------------	-------------------------

Section Tested

unit 1

- 1 Heating flow & Return (Riser)
- 2 Heating flow & Return Ground floor & first floor
- 3 Hot and cold (Riser)
- 4 Hot and cold - Serving all w.c., Ground & first floor
- 5 outside Tap - cold
- 6

Details of Test

Final Working Pressure of Supply 6 Bar Test pressure Applied 6 Bar
Duration of Test 1 Hours 0 Minutes Pass Fail

Testing Engineer A. Hart on behalf of Paine Manwaring Limited

Witnessed by [Signature] on behalf of W.S. LIMITED

Print Name Here C.A. JENNINGS



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03768

Pressure Test Certificate

Contract Southern Gate w. stirland	Job No: CH 035043	Test Date 30-01-2018
---------------------------------------	----------------------	-------------------------

Section Tested

- 1 unit 1 - Ground floor heating system, pipework and
- 2 Radiators
- 3
- 4
- 5
- 6 2 bar air test

Details of Test

Final Working Pressure of Supply 2 Bar Test pressure Applied 2 Bar
Duration of Test 1 Hours 0 Minutes Pass Fail

Testing Engineer R. Jones on behalf of Paine Manwaring Limited

Witnessed by John Sims on behalf of w. stirland

Print Name Here John Sims



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03769

Pressure Test Certificate

Contract <i>Southern Gate w.stirland</i>	Job No: <i>CH035043</i>	Test Date <i>1-02-18</i>
--	----------------------------	-----------------------------

Section Tested

- unit 1 - first floor heating system, pipework and radiators*
-
-
-
-
-

Details of Test

Final Working Pressure of Supply *2* Bar Test pressure Applied *2* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *R Jones* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of *w.stirland*

Print Name Here *John Sims (Site Manager)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03864

Pressure Test Certificate

Contract <i>Southern gate w. Stirland</i>	Job No: <i>CH035043</i>	Test Date <i>20.03.18</i>
---	----------------------------	------------------------------

Section Tested *Unit 1*

- heating circuit in WC areas*
- Riser & all WC areas*
-
-
-
-

Details of Test

Final Working Pressure of Supply *2* Bar Test pressure Applied *2* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *J. Mason* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of *w. Stirland*

Print Name Here *John Sims (SITE MANAGER)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03767

Pressure Test Certificate

Contract Southern Gate w.Stirland	Job No: CH03S043	Test Date 8-01-2018
--------------------------------------	---------------------	------------------------

Section Tested unit 2

- 1 Heating flow and return (Riser)
- 2 Heating flow and return (Ground floor)
- 3 HOT and cold (Riser)
- 4 HOT and cold - serving all w.c., Ground & first floor
- 5 outside Tap - cold
- 6 6 bar - water pressure Test

Details of Test

Final Working Pressure of Supply.....6.....Bar Test pressure Applied.....6.....Bar
Duration of Test.....1.....Hours.....0.....Minutes Pass.......... Fail.....

Testing Engineer.....R. Jones..... on behalf of Paine Manwaring Limited

Witnessed by.....*John Sims*..... on behalf of.....w.Stirland.....

Print Name Here.....*[Signature]*.....



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03863

Pressure Test Certificate

Contract <u>Southern Gate</u> <u>w. Sturland</u>	Job No: <u>CH035043</u>	Test Date <u>07.03.17</u>
---	----------------------------	------------------------------

Section Tested Unit 2

- 1 heating circuit in WC areas
- 2 Riser & all WC areas
- 3
- 4
- 5
- 6

Details of Test

Final Working Pressure of Supply.....2.....Bar Test pressure Applied.....2.....Bar
Duration of Test.....1 Hours.....0 Minutes Pass.......... Fail.....

Testing Engineer [Signature] on behalf of Paine Manwaring Limited

Witnessed by [Signature] on behalf of w. Sturland

Print Name Here JOHN SIMS. (SITE MANAGER)



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03865

Pressure Test Certificate

Contract <i>Southern gate w. Sturland</i>	Job No: <i>CH035043</i>	Test Date <i>07.03.18</i>
---	----------------------------	------------------------------

Section Tested *Unit 2.*

- heating circuit in WC area*
- Riser & all WC circuits*
-
-
-
-

Details of Test

Final Working Pressure of Supply.....*2*.....Bar Test pressure Applied.....*2*.....Bar
Duration of Test.....*1*.....Hours.....*0*.....Minutes Pass.......... Fail.....

Testing Engineer.....*Mason*..... on behalf of Paine Manwaring Limited

Witnessed by.....*[Signature]*..... on behalf of.....*w. Sturland*

Print Name Here.....*JOHN SIMS. (SITE MANAGER.)*.....



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03764

Pressure Test Certificate

Contract <u>Southern Gate</u> <u>w.stirland</u>	Job No: <u>CH035043</u>	Test Date <u>04-01-2018</u>
--	-------------------------	--------------------------------

Section Tested

unit 3

- Heating flow and return (Riser)
- Heating flow and return (groundfloor)
- Hot and cold (Riser)
- Hot and cold - serving all w.c., Ground & first floor
- Outside Tap - COLD
- 6 bar - water pressure TEST

Details of Test

Final Working Pressure of Supply 6 Bar Test pressure Applied 6 Bar
Duration of Test 1 Hours 0 Minutes Pass Fail

Testing Engineer R. Jones on behalf of Paine Manwaring Limited

Witnessed by [Signature] on behalf of w.stirland

Print Name Here C.A. JENNINGS



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03862

Pressure Test Certificate

Contract <i>Southern Gate W. Sturland</i>	Job No: <i>CH035043</i>	Test Date <i>23.02.</i>
---	----------------------------	----------------------------

Section Tested *Unit 43*

- 1 *Second Floor office Rads*
- 2
- 3
- 4
- 5
- 6

Details of Test

Final Working Pressure of Supply *2* Bar Test pressure Applied *2* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *[Signature]* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of *W. Sturland*

Print Name Here *John Sims (Site Manager)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03858

Pressure Test Certificate

Contract <u>Southern Gate</u> <u>W. Sturland</u>	Job No: <u>Ch035043</u>	Test Date <u>22.02.18</u>
---	----------------------------	------------------------------

Section Tested Unit 3

- 1 Ground Floor office Rad's
- 2
- 3
- 4
- 5
- 6

Details of Test

Final Working Pressure of Supply.....2.....Bar Test pressure Applied.....2.....Bar
Duration of Test.....1.....Hours.....0.....Minutes Pass.......... Fail.....

Testing Engineer [Signature] on behalf of Paine Manwaring Limited

Witnessed by [Signature] on behalf of W. Sturland

Print Name Here JOHN SIMS (SITE MANAGER)



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03859

Pressure Test Certificate

Contract <u>Southern gate</u> <u>w. sturland</u>	Job No: <u>CH035043</u>	Test Date <u>23.02.18</u>
---	----------------------------	------------------------------

Section Tested Unit 23

- 1 First Floor office Rads
- 2
- 3
- 4
- 5
- 6

Details of Test

Final Working Pressure of Supply 2 Bar Test pressure Applied 2 Bar
Duration of Test 1 Hours 0 Minutes Pass Fail

Testing Engineer J. Mason on behalf of Paine Manwaring Limited

Witnessed by [Signature] on behalf of w. sturland

Print Name Here JOHN SIMS (SITE MANAGER)

