Certificate of Chlorination (Domestic Systems)

We hereby certify that the installation at:

SOUTHERN SIDINGS UNIT B BLOCKS 1, 2 AND 3

Was disinfected in accordance with BS EN806-5:2012 which incorporates parts of BS6700:2006+A1:2009 6.1.10-6.1.10.4.4

The Approved Code of Practice on Legionella bacteria 2013/HSG274 Section 80-84 Guidance Notes

26 APRIL 2018

- 1 All new hot and cold water services to buildings
- 2 Time commenced 08.00 date 26/04/2018
- 3 Product used for disinfection
- a) Type Sodium Hypochlorite
- b) Volume 300ml (100ml per building)
- 4 Source water used Mains water
- 5 New services swabbed where practicable and flushed—Flushed
- 6 Bio dispersant product (if necessary)
- a) Type N/A
- b) Volume N/A
- 7 Initial level of free chlorine 50ppm
- 8 Level of free chlorine at furthest point from cistern/stop valve 50ppm
- 9 Contact time at least one hour Yes
- 10 Level of free chlorine second disinfection if required N/A
- 11 Final level of free chlorine after final flushing 0.02 ppm
- 12 Free chlorine incoming main 0.02 ppm
- 13 Time completed 11.30 date 26/04/2018

Notes: Samples taken as required

Signed: HM Sneddon

Date: 27th April 2018

Encl: Chlorination procedure

HM&V UTILITIES LTD Unit 23 Basepoint Business Centre Aerodrome Road Gosport Hampshire PO13 0FQ

Tel: 01329 848144 Mob: 07879 650805

Email:info@hmandv.co.uk

Certificate No **1256-18**

Issue (2) Revised 10/02/2015