

PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03855

Pressure Test Certificate

Contract <i>Southern Gate W. Sturland</i>	Job No: <i>CH035043</i>	Test Date <i>19.02.18</i>
---	----------------------------	------------------------------

Section Tested *Unit 1*

- All high level Domestic*
- Hot & cold domestic in Boxing area*
- Riser & all Floors*
- Outside tap & WCs*
-
-

Details of Test

Final Working Pressure of Supply *3* Bar Test pressure Applied *3* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *[Signature]* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of

Print Name Here *JOHN SIMS (SITE MANAGER)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03856

Pressure Test Certificate

Contract <u>Southern Gate</u> <u>w. Sturland</u>	Job No: <u>CH035043</u>	Test Date <u>20.02.18</u>
---	----------------------------	------------------------------

Section Tested Unit 2

- All high level domestic
- Hot & cold domestic in Boxing areas
- Riser & all Floors
- outside tap & WC's
-
-

Details of Test

Final Working Pressure of Supply.....3.....Bar Test pressure Applied.....3.....Bar
Duration of Test.....1.....Hours.....0.....Minutes Pass.......... Fail.....

Testing Engineer.....A. Mason..... on behalf of Paine Manwaring Limited

Witnessed by.....[Signature]..... on behalf of w. Sturland

Print Name Here JOHN SMITH (SITE MANAGER)



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03857

Pressure Test Certificate

Contract <i>Southern Gate W. Sturland</i>	Job No: <i>CH035043</i>	Test Date <i>20.02.18</i>
---	----------------------------	------------------------------

Section Tested *Unit 3*

- 1 *All high level domestic*
- 2 *Hot & Cold domestic in Boxing Areas*
- 3 *Riser & all Floors*
- 4 *Outside tap & WC's*
- 5
- 6

Details of Test

Final Working Pressure of Supply..... *3* Bar Test pressure Applied..... *3* Bar
Duration of Test..... *1* Hours..... *0* Minutes Pass..... Fail.....

Testing Engineer..... *A. Mason* on behalf of Paine Manwaring Limited

Witnessed by..... *[Signature]* on behalf of..... *W. Sturland*

Print Name Here..... *John Sims (Site Manager)*

