

PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03773

Pressure Test Certificate

Contract <i>Southern Gate</i>	Job No: <i>CH035043</i>	Test Date <i>2-2-18</i>
----------------------------------	----------------------------	----------------------------

Section Tested

- unit 1 - Gas Main - air test*
-
-
-
-
-

Details of Test

Final Working Pressure of Supply *4* Bar Test pressure Applied *4* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *[Signature]* on behalf of Paine Manwaring Limited

Witnessed by *[Signature]* on behalf of *W. STELANO LTD.*

Print Name Here *JOHN SIMS (SITE MANAGER)*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03851

Pressure Test Certificate

Contract <i>Southern Gate w. stirland</i>	Job No: <i>cho 36043</i>	Test Date <i>7-02-18</i>
---	-----------------------------	-----------------------------

Section Tested

- unit 2 - Gas pipework - Air test*
-
-
-
-
-

Details of Test

Final Working Pressure of Supply *4* Bar Test pressure Applied *4* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *R. Jones* on behalf of Paine Manwaring Limited

Witnessed by *John Sims* on behalf of *w. stirland*

Print Name Here *[Signature]*



PAINEMANWARING

Heating • Plumbing • Electrical

Paine Manwaring Ltd.
Heating & Ventilation Engineers
Plumbers & Merchants to the Trade
Real-Fire Specialists

Unit D, Easting Close
Dominion Way, Worthing
West Sussex BN14 8HQ

Tel (01903) 237522
Fax (01903) 236511
enquiries@painemanawaring.co.uk
www.painemanawaring.co.uk

03852

Pressure Test Certificate

Contract <i>Southern Gate w. stirland</i>	Job No: <i>CH035043</i>	Test Date <i>07-02-18</i>
---	----------------------------	------------------------------

Section Tested

- unit 3 - Gas pipework - air test*
-
-
-
-
-

Details of Test

Final Working Pressure of Supply *4* Bar Test pressure Applied *4* Bar
Duration of Test *1* Hours *0* Minutes Pass Fail

Testing Engineer *R. Jones* on behalf of Paine Manwaring Limited

Witnessed by *John Sims* on behalf of *w. stirland*

Print Name Here *[Signature]*

