

Fire Alarm Acceptance Certificate

DOCKET No.

106597



Southern Fire Alarms Ltd
2 Argyle Circus
Bognor Regis
West Sussex
PO21 1DS

t: 01243 870851
e: info@sfa-uk.com
w: www.sfa-uk.com

SFA Job No.	30465
Customer Name:	Paine Manwaring Electrical
Site Name:	Southern Gate Unit 2
Address:	
Post Code:	PO19
Date:	19/04/18
Engineer:	Antony Tucker

THE EXTENT OF LIABILITY OF THE SIGNATORY IS LIMITED TO THE SYSTEM DESCRIBED BELOW.

Extent of system covered by this certificate:

Commissioned new fire alarm system.

The following checks have been carried out:

Y	N	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- All installation work appears to be satisfactory.
- The system is capable of giving a fire alarm signal.
- The facility for remote transmission of alarms to an alarm receiving centre operates correctly.
- A suitable zone plan (or other suitable diagrammatic representation) of the premises is provided adjacent to the control panel.

Comments:

na

The following documents have been provided to the purchaser or user:

Y	N	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

- "As fitted" drawings.
- Operating and maintenance instructions.
- Certificates of design, installation and commissioning.
- A log book.
- All relevant tests, defined in the purchasing specification, have been witnessed.
- Sufficient representatives of the user have been properly instructed in the use of the system, including, at least, all means of triggering fire alarm signals, silencing and resetting the system and avoidance of false alarms.

Comments:

na

The following work is required before the system can be accepted:

na

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the acceptance of the fire alarm system, particulars of which are set out above, ACCEPT the system on behalf of:

Customer Name: rowley Company Name: paine manwaring

Customer Signature: Position: contract manager Date: 19/04/18