

# EVC Commissioning Certificate

DOCKET No.

106593



Southern Fire Alarms Ltd  
2 Argyle Circus  
Bognor Regis  
West Sussex  
PO21 1DS

t: 01243 870851  
e: info@sfa-uk.com  
w: www.sfa-uk.com

SFA Job No.	30465
Customer Name:	Paine Manwaring Electrical
Site Name:	Southern Gate Unit 1
Address:	Chichester
Post Code:	PO19
Date:	19/04/18
Engineer:	Antony Tucker

Design Responsibility: SFA  Others

You are advised to maintain records of the EVC system for the lifetime of the system.

**THE EXTENT OF LIABILITY OF THE SIGNATORY IS LIMITED TO THE SYSTEM DESCRIBED BELOW.**

**Extent of system covered by this certificate:**

Commissioned new refuge system as per drawings 545/TSP/01/00/DR/A/2001 AND 2002.

**Variations from the recommendations of BS 5839-9:2011, Clause 22**

1	no new variations
2	
3	
4	
5	

Y	N	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

All equipment operates correctly

Installation work is as far as can be reasonably ascertained, of an acceptable standard

The entire system has been inspected and tested in accordance with BS5839-9:2011, Clause 22

The documentation described in BS5839-9:2011, Clause 23 has been provided to the user.

The system performs as required by the specification prepared by 545/tsp/01/00/dr/A/2001 and 2002 rev A.  
..... a copy of which I/we have given.

**The following work should be completed before/after (delete as applicable) the system becomes operational:**

na

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the commissioning of the EVC system, particulars of which are set out above, CERTIFY that the said installation for which I/we have been responsible conforms to the best of my/our knowledge and belief with the recommendations of BS 5839-9:2011, Clause 22 except for the variations, if any, stated in this certificate.

Engineers Signature:  Print: Antony Tucker Date: 19/04/18

*For and on behalf of: Southern Fire Alarms Ltd, 2 Argyle Circus, Bognor Regis, West Sussex, PO21 1DS*