

HM&V UTILITIES LTD Unit 22, Gosport Business Centre, Aerodrome Road Gosport, Hants PO13 0FQ Telephone: 01329 848144 Fax: 07043 079960 Mobile: 07879 650805		DATE: 26th April 2018 REPORT NO 153-18 CONTRACT OUR REF:			
CUSTOMER ADDRESS: PAINE MANWARING LIMITED <p style="text-align: center;">HEATING</p>		SITE: SOUTHERN SIDINGS UNIT B BLOCK 1			
PARAMETER	MAINS	12.30	13.30	14.40	
pH	7.4	8.2	7.9	7.4	
Conductivity/TDS	305	350	310	304	
p.Alk					
m.Alk					
OH.Alk					
Chloride		0.0			
Ca/Total Hardness					
Concentration Ratio					
Iron		0.0			
Turbidity		CLOUDY	CLEAR	CLEAR	
Bacteria					
Nitrate					
Sulphite					
Glycol					
Copper		0.0			
Molybdate				2%	
Meter Reading					
Comments and actions : Mains flush then dosed with inhibitor and Biocide Recommended level of Molybdate is above 1%					
Water treatment chemical	Dose	Time			
M27	3 litres				
Biocide	500ml				